

THE CORPORATION OF TAY VALLEY TOWNSHIP
REPLACEMENT OF THE BOLINGBROKE BRIDGE
CONTRACT #2020-PW-011

ADDENDUM NO. 1

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE TENDER PACKAGE
AND SHALL FORM PART OF THE CONTRACT DOCUMENTS**

Date Issued: May 28th, 2020
Issued By: Amanda Mabo, Clerk

Please note the following changes, corrections, additions, deletions, information and/or instructions in connection with the Tender Package. Failure to acknowledge receipt of this Addendum as per Part “A” – Information to Bidders may render your submission non-responsive.

This addendum is to address the following questions and/or clarification:

Questions & Answers:

Q1: What is the projected start date of the project?

A1: Construction is scheduled to commence on August 15th, 2020, after the barn swallow nesting season is finished.

Q2: On Drawing No. 1- Scope of work- The Bell line pole and line is to be relocated. On Page 11 of 63, no. 4 states The Township will be responsible for the relocation of utilities where required. Please clarify who's responsible for this.

A2: The Township will be responsible for the pole and line relocation. This work will be completed prior to the commencement of construction.

Q3: In Special Provisions, C2, C3 and C4 mention a geotechnical report. Can you release this please as this is an important part of the tender documents?

A3: The Geotechnical report has been added to the Tender Page of the Township's website.

Q4: 1- Can you please confirm what the 125m² of Geotextile will be used for and what class is to be used.

A4: The geotextile is to be placed under the rip-rap. Due to lapping and contingency the quantity was placed at 125m². The type of geotextile to be used in the Contract shall be as referenced in OPSS.MUNI 511 – Rip-Rap, Rock Protection, and Granular Sheeting.

511.05.02 Geotextile

Geotextile shall be nonwoven, Class II according to OPSS 1860, with an FOS of 75-150 µm, unless otherwise specified in the Contract Documents.

**THE CORPORATION OF TAY VALLEY TOWNSHIP
REPLACEMENT OF THE BOLINGBROKE BRIDGE
CONTRACT #2020-PW-011**

ADDENDUM NO. 1

End of Addendum No. 1

Amanda Mabo, Clerk
clerk@tayvalleytwp.ca