

**THE CORPORATION OF TAY VALLEY TOWNSHIP
REPLACEMENT OF THE BOLINGBROKE BRIDGE
CONTRACT #2020-PW-011
PART "C" – SPECIAL PROVISIONS**

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE TENDER PACKAGE
AND SHALL FORM PART OF THE CONTRACT DOCUMENTS**

Date Issued: June 4, 2020
Issued By: Amanda Mabo, Clerk

Please note the following changes, corrections, additions, deletions, information and/or instructions in connection with the Tender Package. Failure to acknowledge receipt of this Addendum as per Part "A" – Information to Bidders may render your submission non-responsive.

This addendum is to address the following questions and/or clarification:

Clarifications:

Item C11 – Permanent Modular Bridge, item 4.01b) ii shall be deleted in its entirety and replaced with "Fatigue design shall be based on a Highway Class D"

Questions & Answers:

Q1: Please clarify if there are studs on the existing girders. If no information available, what is the assumption to be as the price will vary based on your answer.

A1: It is unknown if there are studs on the existing girders and the contractor should bid accordingly.

Q2: As per Add. #2 page 3 of 6 states that Item B9 Hot Mix HL-3 has been deleted and replaced with Warm Mix SP 12.5 but the Item in the new list of items still says Hot Mix HL-3. Please clarify what is to be used.

A2: Warm Mix shall be used

Q3: Item # B9. Please clarify where the lines are painted and what colour.

A3: Lines shall be "Solid Yellow, 10cm" along center of road as indicated on Sheet 5 – Grading and Paving within the drawing package.

End of Addendum No. 3

Amanda Mabo, Clerk
clerk@tayvalleytwp.ca